



**GOVERNMENT OF SINDH  
SOCIAL PROTECTION STRATEGY UNIT  
CHIEF MINISTER'S SECRETARIAT**

**Queries & Clarifications.**

Contract Title: Hardware & Miscellaneous Items for DATA Center

RFB Reference No: PK-SPU-247839-GO-RFB

Q1 It is requested to please extend the deadline as it require survey & clarity about the solution. Also would request you to please arrange a pre-bid meeting for the clarification. Also require clarity on payment terms.

Clarification:

- The deadline for submission of bids i.e. 01-11-2021, 11:00 AM cannot be extended as it is approved by Procuring Agency and the World Bank.
- Pre bid meeting is not scheduled in the RFB that has been published therefore all queries may be answered through written clarification in accordance with ITB # 7.1.
- Terms of Payment are specified in General Conditions of Contract.

Q2 Please let us know a suitable time and Point of Contact for a technical survey for fiber deployment BOQ.

Q3 Please share the location address for the internet connectivity.

Clarification: Your team may conduct a technical survey on Project site i.e. 5<sup>th</sup> floor, State Life Building # 11, Abdullah Haroon Road Saddar, Karachi.

Q4 You have mentioned page # 81 S# 4.1, HCI Software Solution OEM HW certification with at-least 06 major HW players can you please clarify us.

Clarification: Required certificate from principle that required solution is compatible.

Q5 You have mentioned delivery time in 30 days. Can you know at this moment subject to availability of Parts and cargo facilities/logistics from production regions will be delayed please extend the delivery time.

Clarification: Delivery time of goods / services (30 days), cannot be extended as agreed by the Procuring Agency & World Bank.

Q6 You have mentioned in subject tender in Page # 71 and Section VII- schedule of requirement, Items of Serial from # 22 to 42 is factory fitted in Micro Data Center (SR # 21). So we need to clarify the bundled price you need or quoted individual price of each items?

Clarification: Please quote the individual price for each item.

Q7 You have mentioned SR# 26 PDU (16A) Qty.2 required whereas technical specification (Page # 89) it is mentioned 4.

Clarification: Qty is 2+2 = 4 as provided in specs

Page 1 of 2



**GOVERNMENT OF SINDH  
SOCIAL PROTECTION STRATEGY UNIT  
CHIEF MINISTER'S SECRETARIAT**

Q8 Refer to technical specification page# 89 Sr # 9.2 parallel set: a specific model VRP 11 is mentioned whereas each manufacturer provides their own.

Clarification: Can Provide Parallel kit for the UPS manufactured by any reliable manufacturer

Q9 Refer to technical specification page # 91 S# 18, ATS: It is mentioned ATS in Heading whereas specification and attached SLD layout is of Main distribution board need clarification.

Clarification: Site survey to be advised for actual Design

Q10 Refer to technical specification page # 92 S# 20, IP Base Access control system: Please confirm this system required with micro data center (factory fitted) or conventional standalone system.

Clarification: Conventional

Q11 Attached layouts are for conventional server room, whereas the tender requirement is for micro data center (All in One Solution). Please clarify.

Clarification: Survey for site design to be advised

Q12 Please confirm supply of main power cable from building power room to Micro Data Center is in Scope of customer or vendor, as there is such no requirement mentioned in RFP.

Clarification: Vendor

Q13 We are requested to please allow us to survey of data center for clarification and site measurements.

Clarification: Survey of Site is advised / permitted.